

# **Discovery**

## **Manual Call Point**



Product overview	
Product	Discovery Manual Call Point
Part No.	58100-910
Product	Discovery Manual Call Point with Isolator
Part No.	58100-908
Digital Communication	Discovery (XP95 and CoreProtocol® compatible)

Compliance	
C€	(LPCB)

#### **Product information**

The Discovery Manual Call Point (MCP) is designed to operate on a loop of intelligent fire detection devices. When activated it interrupts the polling cycle for a very fast response.

- · Resettable operating element
- · Easy access, front reset mechanism
- Ergonomic reset key and keyring hole
- · Front facing accessible addressing for commissioning
- E-Z fit first fix terminals for installation (indoor only)
- Flashing polling LED option
- EN 54 -11 and EN 54-17: 2005 certified
- 170° viewable LED indicator

#### **Technical data**

All data is supplied subject to change without notice. Specifications are typical at 24V, 25°C, and 50% RH unless otherwise stated.

Call point typeDeformable elementCall point principleOperation of a switch

Alarm indicator Red light emitting diode (LED)

Fault indicator Amber/Yellow LED

Supply wiring Two-wire supply, polarity sensitive

**Loop connections** Terminal block L1 -ve/L2 +ve

Supply voltage17 - 28 V dcQuiescent current $100 \mu A$ Power up surge1 mA

Maximum power-up time One second

Communications protocol Discovery (XP95 and CoreProtocol compatible)

Modulation voltage 5 - 9 V peak to peak

Alarm current, LED illuminated 4 mA
Normal analogue value 16
Alarm state value 64

Operating temperature  $-20^{\circ}\text{C}$  to  $60^{\circ}\text{C}$ Humidity (no condensing or 0% to 95% RH

icing)

Standards and approvals EN 54-11,

EN 54-17: 2005 (isolated

version) CPR, LPCB

IP rating IP24D

**Dimensions** 89mm wide x 93 mm high x 26.5

mm depth

Weight 110 g (flush mounted)

160 g (surface mounted)

Materials Flame-retardant polycarbonate

36 Brookside Road, Havant Hampshire, PO9 1JR, UK. Tel: +44 (0)23 9249 2412 Fax: +44 (0)23 9249 2754 Email: sales@apollo-fire.com Web: www.apollo-fire.co.uk All information in this document is given in good faith but Apollo Fire Detectors Ltd cannot be held responsible for any omissions or errors. The company reserves the right to change the specifications of products at any time and without prior notice.











#### Operation

The address of each Discovery MCP is set at the commissioning stage by means of a seven-segment DIL switch. If a MCP is activated, it interrupts the normal protocol to give a fast response.

A single bi-coloured alarm LED is provided on the call point. This LED is controlled, independently of the call point, by the control panel and may be set to flash each time the call point is polled. The red LED is lit when the call point has been activated and sent into alarm. On the isolated versions an amber/yellow LED indicates a short-circuit on the loop wiring either side of the call point.

Call points can be remotely tested from the panel by transmission of a single bit in the communications protocol. Call points respond by providing a value of 64 which corresponds to the alarm value. The panel should recognise this response as a test signal and should not raise a general alarm.

Discovery MCPs are available with or without an isolator. Each version is available with a resettable element and a backbox for surface mounting as standard. If a glass option is required, spare glasses are available on request.

For ease of installation Discovery MCPs are supplied with clip-on terminal blocks and a connector which allows continuity testing before call points are commissioned.

To provide additional protection against accidental operation, a transparent hinged cover with a locking tag is available, which can be fitted to the MCP. Please note that the call point does not conform to EN54-11 when this lid is fitted and secured with the locking tag.

### EMC Directive 2014/30/EU

The Discovery MCP complies with the essential requirements of the EMC Directive 2014/30/EU, provided that it is used as described in this datasheet

A copy of the Declaration of Conformity is available from the Apollo website: www.apollo-fire.co.uk

Conformity of the Discovery MCP with the EMC Directive, does not confer compliance with the directive on any apparatus or systems connected to them.

#### Construction Products Regulation 305/2011/EU

The Discovery MCP complies with the essential requirements of the Construction Products Regulation 305/2011/EU.

A copy of the Declaration of Performance is available from the Apollo website: www.apollo-fire.co.uk

Discovery Manual Call Point accessories	
Product	Hinged cover and locking tag
Part No.	26729-152
Product	Locking tags (pack of 5)
Part No.	26729-179

